



Inspecta Estonia OÜ has granted a product certificate to attest that the product

**Corrugated double wall cable conduits for buried underground applications**

placed on the market by

**Pipelife Eesti AS**

Põrguvälja tee 4, Lehmja küla, 75306 Rae vald, Harju maakond, ESTONIA

and produced in the factory

**Pipelife Eesti AS**

Põrguvälja tee 4, Lehmja küla, 75306 Rae vald, Harju maakond, ESTONIA

has following performances:

Nominal outside diameter dn [mm]	Resistance to compression		Bending	Resistance to impact (class)
	[N]	(type)		
50	450	450	pliable	N (normal)
50	450	450	rigid	
50	750	750	rigid	
75	450	450	pliable	
75	450	450	rigid	
75	750	750	rigid	
110	450	450	pliable	
110	450	450	rigid	
110	750	750	rigid	
160	450	450	pliable	
160	450	450	rigid	
160	750	750	rigid	

The company has a working product management system that has been implemented in accordance with the requirements of EN16386-24:2010.

The manufacturer is testing the samples taken at the factory in accordance with prescribed test plan. Inspecta Estonia OÜ has performed type testing, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate is issued on **18.06.2019** and remains valid until **17.06.2024**, as long as the manufacturing conditions in the factory or the FPC itself are not modified significantly. The validity of the certificate can be checked on the Internet at [www.kiwa.com/ee](http://www.kiwa.com/ee).

German Virm  
Head of the conformity assessment department

Tallinn 18.06.2019

