

DECLARATION OF CONFORMITY

No. 2019-06-18-02

Product name: Corrugated double wall rigid cable conduits in bars for buried underground applications

Product identification element: EN 61386-24 CABLE PROTECTION N 450

Product technical regulation: EVS-EN 61386-24:2010 Conduit systems for cable management - Part 24: Particular requirements - Conduit systems buried underground

Product application area: Cable conduits for buried underground applications

| Declared product properties | Code | Unit | Value | Method |
|-----------------------------|------|------|---|----------------------|
| Material | - | - | Polyethylene (PE) and/or polypropylene (PP) | - |
| Nominal outside diameter | - | mm | 50, 75, 110, 160 | EVS-EN 61386-24:2010 |
| Resistance to compression | 450 | N | 450 | |
| Resistance to impact | N | - | Normal: 5 kg | |
| Resistance to bending | - | - | Rigid | |

Manufacturer: Pipelife Eesti AS
Põrguvälja tee 4, Lehmja, Rae vald, Harjumaa 75306, Estonia

Place of manufacturing: Pipelife Eesti AS
Põrguvälja tee 4, Lehmja, Rae vald, Harjumaa 75306, Estonia

With this declaration of conformity Pipelife Eesti AS declares that the products conform to the requirements as stated in above mentioned product technical regulations and declared product properties.

Pipelife Eesti AS holds the product certificate no ET-0243-19 issued by Inspecta Estonia OÜ assuring that above mentioned products conform to the above mentioned requirements.

Pipelife Eesti AS holds the certificate of conformity no Q-025-18 issued by Inspecta Estonia OÜ assuring that the quality management system of Pipelife Eesti AS conforms to the requirements of the standard ISO 9001:2015.

Issue date: 18th of June 2019

Signed by: 
Lembit Salla
Pipelife Eesti AS Plant Manager



Inspecta Estonia OÜ