



ORGANIZATION FOR EXECUTION OF COMMON ACTIVITIES

IN THE GAS INDUSTRY OF THE CZECH REPUBLIC

CERTIFICATE **of registration No. 0063/2003**

Product: *Pressure pipes with protection layer ROBUST PIPE*

Code of product: **936, 945**

Applicant: *PELIFE-FATRA s. r. o.*
Kučovaniny, 765 02 Otrokovice

Manufacturer: *PELIFE-FATRA s. r. o.*
Kučovaniny, 765 02 Otrokovice

The registered product has been subjected to conformity assessment to stipulated requirements addressing quality of products used in the gas industry. Certification and registration body confirms herewith that the properties of the product in question are in conformity with requirements laid down in CP 15-26-2003.

The assessment report No. 89/2002 of 7. April 2003 is the integral part of the certificate.

Basic technical data:

Basic pipe: **PE 100 (ELTEX TUB 121, BOREALIS HE 3490 LS) SDR 11 and 17,6,**
Coating: **foam polyethylene (PEHD),**
Diameters d_n : **20, 25, 32, 40, 50, 63, 75, 90, 110, 125, 160, 180, 200, 225,**
Colour: **yellow (basic pipe: black with orange-yellow identification stripes),**
Medium: **natural gas, town gas, biogas and gaseous propane,**
Use: **without the backfill with grains up to 63 mm and for trenchless technologies without a sleeve.**

The product is registered in the products registration system of GAS s. r. o. and the applicant is granted the licence to use the Quality Mark CG.

The graphic image of the Quality Mark is as follows:



Validity of the certificate is subject to a positive result of the inspection carried out at least once a year in the operational phase of this certificate.

Validity of the certificate: **unlimited**

Prague: 14. April 2003

Head of COV



Chief Executive of GAS s. r. o.